ENDYNE Inc.
Environmental Laboratories

Laboratory Report

Champlain Valley Edu Services	200674
1585 Military Turnpike	
Plattsburgh, NY 12901	
Atten: Stephanie Trombly	

PROJECT: Lead in School Taps, Moriah CS

WORK ORDER: **2510-37392**

DATE RECEIVED: October 22, 2025

DATE REPORTED: November 06, 2025

SAMPLER: Not Given

Enclosed please find the results of the analyses performed for the samples referenced on the attached chain of custody located at the end of this report.

The column labeled Lab/Tech in the accompanying report denotes the laboratory facility where the testing was performed and the technician who conducted the assay. A "W" designates the Williston, VT lab under NELAC certification ELAP 11263; "R" designates the Lebanon, NH facility under certification NH 2037 and "N" the Plattsburgh, NY lab under certification ELAP 11892. "Sub" indicates the testing was performed by a subcontracted laboratory. The accreditation status of the subcontracted lab is referenced in the corresponding NELAC and Qual fields.

This NELAC column also denotes the accreditation status of each laboratory for each reported parameter. "A" indicates the referenced laboratory is NELAC accredited for the parameter reported. "N" indicates the laboratory is not accredited. "U" indicates that NELAC does not offer accreditation for that parameter in that specific matrix. Test results denoted with an "A" meet all National Environmental Laboratory Accreditation Program requirements except where denoted by pertinent data qualifiers. Test results are representative of the samples as they were received at the laboratory.

Endyne, Inc. warrants, to the best of its knowledge and belief, the accuracy of the analytical test results contained in this report, but makes no other warranty, expressed or implied, especially no warranties of merchantability or fitness for a particular purpose.

Reviewed by:

Christina A Lafountain
Laboratory Director Plattsburgh, NY

Laboratory Report

CLIENT: Champlain Valley Edu Services
PROJECT: Lead in School Taps, Moriah CS

WORK ORDER: **2510-37392**
DATE RECEIVED: 10/22/25

001 Site: KS4 — Stagnant: 10.02 Hrs Date Sampled: 10/21/25 Time: 5:01

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	11/4/25	W MGT	A	

002 Site: KS5 — Stagnant: 10.03 Hrs Date Sampled: 10/21/25 Time: 5:02

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	11/4/25	W MGT	A	

003 Site: KS6 — Stagnant: 10.05 Hrs Date Sampled: 10/21/25 Time: 5:03

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	11/4/25	W MGT	A	

004 Site: KP1 — Stagnant: 10.07 Hrs Date Sampled: 10/21/25 Time: 5:04

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	11/4/25	W MGT	A	

005 Site: KP2 — Stagnant: 10.08 Hrs Date Sampled: 10/21/25 Time: 5:05

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0042	mg/L	EPA 200.8	11/4/25	W MGT	A	

006 Site: BR1 — Stagnant: 10.10 Hrs Date Sampled: 10/21/25 Time: 5:06

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	11/4/25	W MGT	A	

007 Site: F1 — Stagnant: 10.12 Hrs Date Sampled: 10/21/25 Time: 5:07

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	11/4/25	W MGT	A	

008 Site: F15 — Stagnant: 10.13 Hrs Date Sampled: 10/21/25 Time: 5:08

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	11/4/25	W MGT	A	

009 Site: Rm 114 S1 — Stagnant: 10.15 Hrs Date Sampled: 10/21/25 Time: 5:09

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	11/4/25	W MGT	A	

010 Site: Rm 114 S2 — Stagnant: 10.17 Hrs Date Sampled: 10/21/25 Time: 5:10

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.

Laboratory Report

CLIENT: Champlain Valley Edu Services
PROJECT: Lead in School Taps, Moriah CS

WORK ORDER: **2510-37392**
DATE RECEIVED: 10/22/25

Lead, Total	< 0.0010	mg/L	EPA 200.8	11/4/25	W MGT	A	

011 Site: Rm 343 S1 — Stagnant: 10.18 Hrs Date Sampled: 10/21/25 Time: 5:11

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0031	mg/L	EPA 200.8	11/4/25	W MGT	A	

012 Site: Rm 343 S2 — Stagnant: 10.20 Hrs Date Sampled: 10/21/25 Time: 5:12

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	11/4/25	W MGT	A	

013 Site: Rm 343 S3 — Stagnant: 10.22 Hrs Date Sampled: 10/21/25 Time: 5:13

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0025	mg/L	EPA 200.8	11/4/25	W MGT	A	

014 Site: Rm 342 S1 — Stagnant: 10.23 Hrs Date Sampled: 10/21/25 Time: 5:14

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	11/4/25	W MGT	A	

015 Site: F5 — Stagnant: 10.25 Hrs Date Sampled: 10/21/25 Time: 5:15

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	11/4/25	W MGT	A	

016 Site: Rm 501 S1 — Stagnant: 10.27 Hrs Date Sampled: 10/21/25 Time: 5:16

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	11/4/25	W MGT	A	

017 Site: F6 — Stagnant: 10.28 Hrs Date Sampled: 10/21/25 Time: 5:17

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	11/4/25	W MGT	A	

018 Site: F7 — Stagnant: 10.30 Hrs Date Sampled: 10/21/25 Time: 5:18

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	11/4/25	W MGT	A	

019 Site: Rm 389 S1 — Stagnant: 10.32 Hrs Date Sampled: 10/21/25 Time: 5:19

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	11/4/25	W MGT	A	

Laboratory Report

CLIENT: Champlain Valley Edu Services
PROJECT: Lead in School Taps, Moriah CS

WORK ORDER: **2510-37392**
DATE RECEIVED: 10/22/25

020 Site: F10 Stagnant: 10.33 Hrs Date Sampled: 10/21/25 Time: 5:20

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	11/4/25	W MGT	A	

021 Site: Rm 118 S1 Stagnant: 10.35 Hrs Date Sampled: 10/21/25 Time: 5:21

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	11/4/25	W MGT	A	

022 Site: F8 Stagnant: 10.37 Hrs Date Sampled: 10/21/25 Time: 5:22

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	11/4/25	W MGT	A	

023 Site: F9 Stagnant: 10.38 Hrs Date Sampled: 10/21/25 Time: 5:23

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	11/4/25	W MGT	A	

024 Site: F13 Stagnant: 10.40 Hrs Date Sampled: 10/21/25 Time: 5:24

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	11/4/25	W MGT	A	

025 Site: Rm 145 S1 Stagnant: 10.42 Hrs Date Sampled: 10/21/25 Time: 5:25

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	11/4/25	W MGT	A	

026 Site: Rm 146 S1 Stagnant: 10.43 Hrs Date Sampled: 10/21/25 Time: 5:26

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	11/4/25	W MGT	A	

027 Site: Rm 147 S1 Stagnant: 10.45 Hrs Date Sampled: 10/21/25 Time: 5:27

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	11/4/25	W MGT	A	

028 Site: Rm 148 S1 Stagnant: 10.47 Hrs Date Sampled: 10/21/25 Time: 5:28

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	11/4/25	W MGT	A	

029 Site: F11 Stagnant: 10.48 Hrs Date Sampled: 10/21/25 Time: 5:29

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.

Laboratory Report

CLIENT:	Champlain Valley Edu Services	WORK ORDER:	**2510-37392**
PROJECT:	Lead in School Taps, Moriah CS	DATE RECEIVED:	10/22/25

Lead, Total	< 0.0010	mg/L	EPA 200.8	11/5/25	W MGT	A	

030 Site: Rm 206 S1 Stagnant: 10.50 Hrs Date Sampled: 10/21/25 Time: 5:30

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	11/5/25	W MGT	A	

031 Site: F12 Stagnant: 10.52 Hrs Date Sampled: 10/21/25 Time: 5:31

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	11/5/25	W MGT	A	

032 Site: Rm 222 S1 Stagnant: 10.53 Hrs Date Sampled: 10/21/25 Time: 5:32

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	11/5/25	W MGT	A	

033 Site: Rm 225 S1 Stagnant: 10.55 Hrs Date Sampled: 10/21/25 Time: 5:33

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	11/5/25	W MGT	A	

034 Site: F3 Stagnant: 10.57 Hrs Date Sampled: 10/21/25 Time: 5:34

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	11/5/25	W MGT	A	

035 Site: Rm 303 S1 Stagnant: 10.58 Hrs Date Sampled: 10/21/25 Time: 5:35

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0019	mg/L	EPA 200.8	11/5/25	W MGT	A	

036 Site: Rm 303 S2 Stagnant: 10.60 Hrs Date Sampled: 10/21/25 Time: 5:36

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0015	mg/L	EPA 200.8	11/5/25	W MGT	A	

037 Site: Rm 305 S1 Stagnant: 10.62 Hrs Date Sampled: 10/21/25 Time: 5:37

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	11/5/25	W MGT	A	

038 Site: F2 Stagnant: 10.63 Hrs Date Sampled: 10/21/25 Time: 5:38

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	11/5/25	W MGT	A	

Laboratory Report

CLIENT: Champlain Valley Edu Services
PROJECT: Lead in School Taps, Moriah CS

WORK ORDER: **2510-37392**
DATE RECEIVED: 10/22/25

039 | Site: F4 | Stagnant: 10.65 Hrs | Date Sampled: 10/21/25 | Time: 5:39

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	11/5/25	W MGT	A	

040 | Site: LF S1 | Stagnant: 10.67 Hrs | Date Sampled: 10/21/25 | Time: 5:40

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0019	mg/L	EPA 200.8	11/5/25	W MGT	A	

041 | Site: LF S2 | Stagnant: 10.67 Hrs | Date Sampled: 10/21/25 | Time: 5:40

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0067	mg/L	EPA 200.8	11/5/25	W MGT	A	

042 | Site: BGS1 | Stagnant: 10.70 Hrs | Date Sampled: 10/21/25 | Time: 5:42

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	11/5/25	W MGT	A	

043 | Site: BGS2 | Stagnant: 10.72 Hrs | Date Sampled: 10/21/25 | Time: 5:43

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	11/5/25	W MGT	A	

Test results comply with all NELAC requirements unless otherwise noted. This Laboratory Report includes the client's COC sample documentation and shall not be reproduced except in full, without written approval of the laboratory.

Endyne, Inc. - Plattsburgh Lab

LAB USE ONLY
Due Date:

315 New York Road
Plattsburgh, NY 12903
Phone (518)563-1720

Fax (518)563-0052
info@endynelabs.com
ELAP #11892

Client: Moriah Central School | Account #: 200674

Email Address: JKarlo@Moriahk12.org

Contact Person: Joe Karlo

Phone: 518-546-3301 Ex 3357

PO # 24-00012 (CVES)

Project Name: 3T - Lead in Schools

SAMPLE SUPPLY INFORMATION

PWS # Moriah W.D.

Collection Address: Moriah Central School, 39 Viking Lane

City: Port Henry State: NY Zip: 12974

Pag 1 of 2

Collector's Name:

SAMPLE MATRIX CODES
DW=drinking water SW+Surface Water
WW=waste water SD=solid
MW=monitoring well SO=soil
HW=hazardous waste SL=sludge

Compliance? Yes
Initial Testing or Repeat Testing

TURNAROUND TIME REQUESTED
Standard (2-4 weeks)

Analysis Requested:

	Sample ID / Collection Site	Date/Time		Bottle Tyoe / Volume	Matrix	Preservation	First Draw (Y)	Flushed Line (Y)	Total Lead		Water Last Used (Date / Time)	Lab Use Sample #
1	KS4	10/21	5:01AM	250mL, P	DW	*	Y	N	X		10/20 7PM	001
2	KS5		5:02AM	250mL, P	DW	*	Y	N	X			002
3	KS6		5:03AM	250mL, P	DW	*	Y	N	X			003
4	KP1		5:04AM	250mL, P	DW	*	Y	N	X			004
5	KP2		5:05AM	250mL, P	DW	*	Y	N	X			005
6	BR1		5:06AM	250mL, P	DW	*	Y	N	X			006
7	F1		5:07AM	250mL, P	DW	*	Y	N	X			007
8	F15		5:08AM	250mL, P	DW	*	Y	N	X			008
9	RM 114 S1		5:09AM	250mL, P	DW	*	Y	N	X			009
10	RM 114 S2		5:10AM	250mL, P	DW	*	Y	N	X			010
11	RM 343 S1		5:11AM	250mL, P	DW	*	Y	N	X			011
12	RM 343 S2	10/21	5:12AM	250mL, P	DW	*	Y	N	X		10/20 7PM	012

SAMPLE RECEIPT (Lab Use Only)	Date	Time	Sample Relinquished By (SIGN HERE)	Samples Received By
Samples Intact?				AndWV 22Oct25
Filled to proper volume?				@0943
# of Containers				

* Samples preserved with NHO3 to pH < 2 after receipt at the lab.

Note: Results are emailed to the Health Department at the same time as the client unless otherwise noted on the COC.

2510-37392

2510-37392
Champlain Valley Edu Services
Lead in School Taps, Moriah CS

OFFICE USE ONLY
Analysis Fee $ ______ or A/R

Terms are net 30 days with
Payment Method ☐ Cash ☐ Check ☐ MC/Visa ☐ Money Order Check, MO, Receipt # ______

Endyne, Inc. - Plattsburgh Lab

315 New York Road
Plattsburgh, NY 12903
Phone (518)563-1720
Fax (518)563-0052
info@endynelabs.com
ELAP #11892

LAB USE ONLY
Due Date:

Client: Moriah Central School | Account #: 200674 | Collector's Name: Joe Karlo

 | Work Order #

#	Sample ID / Collection Site	Date/Time	Bottle	Matrix	Pres	1st Draw	Flushed Line	Lead, Total	Water Last Used (date/Time)	Sample #
13	RM 343 S3	10/21 5:13AM	250mL, P	DW	*	Y	N	X	10/20 7PM	013
14	RM 342 S1	5:14AM	250mL, P	DW	*			X		014
15	F5	5:15AM	250mL, P	DW	*			X		015
16	RM 501 S1	5:16AM	250mL, P	DW	*			X		016
17	F6	5:17AM	250mL, P	DW	*			X		017
18	F7	5:18AM	250mL, P	DW	*			X		018
19	RM 389 S1	5:19AM	250mL, P	DW	*			X		019
20	F10	5:20AM	250mL, P	DW	*			X		020
21	RM 118 S1	5:21AM	250mL, P	DW	*			X		021
22	F8	5:22AM	250mL, P	DW	*			X		022
23	F9	5:23AM	250mL, P	DW	*			X		023
24	F13	5:24AM	250mL, P	DW	*			X		024
25	RM 145 S1	5:25AM	250mL, P	DW	*			X		025
26	RM 146 S1	5:26AM	250mL, P	DW	*			X		026
27	RM 147 S1	5:27AM	250mL, P	DW	*			X		027
28	RM 148 S1	5:28AM	250mL, P	DW	*			X		028
29	F11	5:29AM	250mL, P	DW	*			X		029
30	RM 206 S1	5:30AM	250mL, P	DW	*			X		030
31	F12	5:31AM	250mL, P	DW	*			X		031
32	RM 222 S1	5:32AM	250mL, P	DW	*			X		032
33	RM 225 S1	5:33AM	250mL, P	DW	*			X		033
34	F3	5:34AM	250mL, P	DW	*			X		034
35	RM 303 S1	5:35AM	250mL, P	DW	*			X		035
36	RM 303 S2	5:36AM	250mL, P	DW	*			X		036
37	RM 305 S1	5:37AM	250mL, P	DW	*			X		037
38	F2	5:38AM	250mL, P	DW	*			X		038
39	F4	5:39AM	250mL, P	DW	*			X		039
40	LF S1	5:40AM	250mL, P	DW	*			X		040
41	LF S2	5:41AM	250mL, P	DW	*			X		041
42	BG S1	5:42AM	250mL, P	DW	*			X		042
43	BG S2	10/21 5:43AM	250mL, P	DW	*	Y	N	X	10/20 7PM	043
44			250mL, P	DW	*			X		044
45			250mL, P	DW	*			X		045
46			250mL, P	DW	*			X		046

Endyne, Inc. - Plattsburgh Lab

LAB USE ONLY
Due Date:

315 New York Road
Plattsburgh, NY 12903
Phone (518)563-1720
Fax (518)563-0052
info@endynelabs.com
ELAP #11892

Client: Moriah Central School	Account #: 200674	SAMPLE SUPPLY INFORMATION	
Email Address: Jkarlo@Moriahk12.org		PWS # Moriah W. D.	
Contact Person: Joe Karlo	Project Name	Collection Address: Moriah Central School	
Phone: 518-546-3301 Ex 3357	3T - Lead in Schools	39 Viking Lane	
PO # 24-00012 (CVES)		City: Port Henry	State: NY Zip: 12974
	Pag 1 of 2	Collector's Name:	

SAMPLE MATRIX CODES
DW=drinking water SW+Surface Water
WW=waste water SD=solid
MW=monitoring well SO=soil
HW=hazardous waste SL=sludge

Compliance? Yes
Initial Testing
or
Repeat Testing

TURNAROUND TIME REQUESTED
Standard (2-4 weeks)

Analysis Requested:

	Sample ID / Collection Site	Date/Time		Bottle Tyoe / Volume	Matrix	Preservation	First Draw (Y)	Flushed Line (Y)	Total Lead		Water Last Used (Date / Time)	Lab Use Sample #
1	KS4	10/21	5:01AM	250mL, P	DW	*	Y	N	X		10/20 7PM	001
2	KS5		5:02AM	250mL, P	DW	*	Y	N	X			002
3	KS6		5:03AM	250mL, P	DW	*	Y	N	X			003
4	KP1		5:04AM	250mL, P	DW	*	Y	N	X			004
5	KP2		5:05AM	250mL, P	DW	*	Y	N	X			005
6	BR1		5:06AM	250mL, P	DW	*	Y	N	X			006
7	F1		5:07AM	250mL, P	DW	*	Y	N	X			007
8	F15		5:08AM	250mL, P	DW	*	Y	N	X			008
9	RM 114 S1		5:09AM	250mL, P	DW	*	Y	N	X			009
10	RM 114 S2		5:10AM	250mL, P	DW	*	Y	N	X			010
11	RM 343 S1		5:11AM	250mL, P	DW	*	Y	N	X			011
12	RM 343 S2	10/21	5:12AM	250mL, P	DW	*	Y	N	X		10/20 7PM	012

SAMPLE RECEIPT (Lab Use Only)	Date	Time	Sample Relinquished By (SIGN HERE)	Samples Received By
Samples Intact?				
Filled to proper volume?				
# of Containers				

* Samples preserved with NHO3 to pH < 2 after receipt at the lab.

Note: Results are emailed to the Health Department at the same time as the client unless otherwise noted on the COC.

OFFICE USE ONLY
Terms are net 30 days with an open, up to date account
Analysis Fee $__________ or A/R Payment Method ☐ Cash ☐ Check ☐ MC/Visa ☐ Money Order Check, MO, Receipt # ______

Endyne, Inc. - Plattsburgh Lab

315 New York Road
Plattsburgh, NY 12903
Phone (518)563-1720
Fax (518)563-0052
info@endynelabs.com
ELAP #11892

LAB USE ONLY
Due Date:

Client: Moriah Central School
Account #: 200674
Collector's Name: Joe Karlo
Page 2 of 2
Work Order #

#	Sample ID / Collection Site	Date/Time	Bottle	Matrix	Pres	1st Draw	Flushed Line	Lead, Total	Water Last Used (date/Time)	Sample #
13	RM 343 S3	10/21 5:13AM	250mL, P	DW	*	Y	N	X	10/20 7PM	013
14	RM 342 S1	5:14AM	250mL, P	DW	*			X		014
15	F5	5:15AM	250mL, P	DW	*			X		015
16	RM 501 S1	5:16AM	250mL, P	DW	*			X		016
17	F6	5:17AM	250mL, P	DW	*			X		017
18	F7	5:18AM	250mL, P	DW	*			X		018
19	RM 389 S1	5:19AM	250mL, P	DW	*			X		019
20	F10	5:20AM	250mL, P	DW	*			X		020
21	RM 118 S1	5:21AM	250mL, P	DW	*			X		021
22	F8	5:22AM	250mL, P	DW	*			X		022
23	F9	5:23AM	250mL, P	DW	*			X		023
24	F13	5:24AM	250mL, P	DW	*			X		024
25	RM 145 S1	5:25AM	250mL, P	DW	*			X		025
26	RM 146 S1	5:26AM	250mL, P	DW	*			X		026
27	RM 147 S1	5:27AM	250mL, P	DW	*			X		027
28	RM 148 S1	5:28AM	250mL, P	DW	*			X		028
29	F11	5:29AM	250mL, P	DW	*			X		029
30	RM 206 S1	5:30AM	250mL, P	DW	*			X		030
31	F12	5:31AM	250mL, P	DW	*			X		031
32	RM 222 S1	5:32AM	250mL, P	DW	*			X		032
33	RM 225 S1	5:33AM	250mL, P	DW	*			X		033
34	F3	5:34AM	250mL, P	DW	*			X		034
35	RM 303 S1	5:35AM	250mL, P	DW	*			X		035
36	RM 303 S2	5:36AM	250mL, P	DW	*			X		036
37	RM 305 S1	5:37AM	250mL, P	DW	*			X		037
38	F2	5:38AM	250mL, P	DW	*			X		038
39	F4	5:39AM	250mL, P	DW	*			X		039
40	LF S1	5:40AM	250mL, P	DW	*			X		040
41	LF S2	5:41AM	250mL, P	DW	*			X		041
42	BG S1	5:42AM	250mL, P	DW	*			X		042
43	BG S2	10/21 5:43AM	250mL, P	DW	*	Y	N	X	10/20 7PM	043
44			250mL, P	DW	*			X		044
45			250mL, P	DW	*			X		045
46			250mL, P	DW	*			X		046